

Cheryl Frazier

From: Roland Bartl
Sent: Monday, December 12, 2011 3:03 PM
To: Cheryl Frazier
Subject: FW: <https://doc.acton-ma.gov/dsweb/View/Collection-4406>

Cheryl:

You received this directly from Bob Craig. Please add it to the docushare file on Leo's upcoming site plan.

Thanks -

Roland Bartl, AICP
Planning Director
472 Main Street
Acton, MA 01720
(978) 929-6631

From: Robert Craig
Sent: Monday, December 12, 2011 12:26 PM
To: Roland Bartl; Frank Ramsbottom; Tom Tidman; Health Department; Planning Department; Engineering Department; Chris Allen
Cc: Cheryl Frazier; Manager Department
Subject: RE: <https://doc.acton-ma.gov/dsweb/View/Collection-4406>

Roland,

I did recheck the plan with Engineering and also made a site visit. I would concur that the access does not include provisions to turn fire and apparatus around once at the proposed structure, assuming all the parking spaces adjacent to the access way are full going into the site. Also I would concur that access to the building appears to be limited once at the building. I saw only the reference to a well for the structure, so it appears that the structure itself would be an excessive distance from a hydrant.

Robert C. Craig
Fire Chief
Acton Fire Department
978-929-7414
978-266-2885(FAX)

From: Roland Bartl
Sent: Thursday, December 08, 2011 2:50 PM
To: Frank Ramsbottom; Tom Tidman; Health Department; Planning Department; Engineering Department; Robert Craig; Chris Allen
Cc: Cheryl Frazier; Manager Department
Subject: RE: <https://doc.acton-ma.gov/dsweb/View/Collection-4406>